


7604D 125VDCXA



SPECIFICATIONS:

NO. OF POSITIONS: 2, TRIP AND RESET

NO. OF SECTIONS: 4

CONTACTS: 2 NORMALLY OPEN
2 NORMALLY CLOSED
PER DECK

ACTION: 45° POSITIVE TRIP DETENT

STATIONARY CONTACTS : SILVER OVER COPPER

NAMEPLATE: AS SHOWN

COIL SPECIFICATIONS:

OPERATING VOLTAGE: 125 VDC / 120 VAC

THRESHOLD VOLTAGE: 16 VDC / 20 VAC

OPERATING RANGE: 30 - 140 VDC / 30 - 140 VAC

CURRENT AT RATED VOLTAGE: 4.6 / 4.4 AMPS



DECK	CONTACTS	POSITION	
		TRIP	RESET
1	11 — — 13		
	12 — — 18	X	X
	15 — — 17		
	16 — — 14	X	X
2	21 — — 23		
	22 — — 28	X	X
	25 — — 27		
	26 — — 24	X	X
3	31 — — 33		
	32 — — 38	X	X
	35 — — 37		
	36 — — 34	X	X
4	41 — — 43		
	42 — — 48	X	X
	45 — — 47		
	46 — — 44	X	X

ELECTRICAL RATINGS:

25 A/120 VAC 3 A/ 125 VDC

15 A/600 VAC 1 A/ 250 VDC

20 A/600 VAC (RESISTIVE)

OVERLOAD CURRENT (50 OPERATIONS):

95 A/120 VAC

65 A/240 VAC


35 A/600 VAC

DIELECTRIC STRENGTH: 2200 VRMS

INSULATION RESISTANCE: 100 MEGOHMS INITIAL

CONTACT RESISTANCE: 10 MILLIOHMS MAX. INITIAL

NAMEPLATE AND PANEL DRILLING DIMENSIONS



CUSTOMER REFERENCE:: TERMINAL SCREW TIGHTENING TORQUE:: 8 IN-LBS.

LOCK-OUT RELAY SPECIFICATION SHEET

7604D 125VDCXA


7604D 125VDCCXA

LOCK-OUT RELAYS (LOR)

GENERAL OPERATION:

THE HANDLE OF THE LOR MUST BE MANUALLY ROTATED CLOCKWISE TO PLACE THE UNIT IN THE "RESET" POSITION (SEE FIGURE A)

FIGURE A - RESET POSITION




7604D 125VDCXA

LED INDICATION

CONDITION #1	
ROTOR	RESET (AS SHOWN)
SWITCH 1 (S1)	OPEN

RESULT	
LEFT LED	ON
RIGHT LED	OFF
SCADA CIRCUIT (TRIP COIL MONITOR)	OPEN



LOCK-OUT RELAY SPECIFICATION SHEET

7604D 125VDCXA


7604D 125VDCCXA

LED INDICATION

CONDITION #2	
ROTOR	RESET (AS SHOWN)
SWITCH 1 (S1)	CLOSED

RESULT	
LEFT LED	OFF
RIGHT LED	ON
SCADA SWITCH	CLOSED

WHEN S1 CLOSES, THE COIL CAUSES A MECHANICAL ROTATION OF THE RELAY RESULTING IN THE SWITCH ROTOR ADVANCE TO THE "TRIP" POSITION SHOWN



LOCK-OUT RELAY SPECIFICATION SHEET

7604D 125VDCCXA


7604D 125VDCCXA

LED INDICATION

CONDITION #2	
ROTOR	RESET (AS SHOWN)
SWITCH 1 (S1)	OPEN

RESULT	
LEFT LED	OFF
RIGHT LED	OFF
SCADA SWITCH	CLOSED

WHEN S1 OPENS, THE RIGHT LED WILL GO OFF. THE SCADA CIRCUIT WILL REMAIN CLOSED UNTIL THE LOCKOUT RELAY IS ROTATED BACK TO THE RESET POSITION.



LOCK-OUT RELAY SPECIFICATION SHEET

7604D 125VDCCXA