

SPECIFICATIONS:

NO. OF POSITIONS: 2, TRIP AND RESET
 NO. OF SECTIONS: 7 (5 ACTIVE, 1 CONTROL, 1 TERM. BRD DECK)
 CONTACTS: 2 NORMALLY OPEN
 2 NORMALLY CLOSED
 PER DECK

ACTION: 45° POSITIVE TRIP DETENT
 STATIONARY CONTACTS : SILVER OVER COPPER
 NAMEPLATE: AS SHOWN

COIL SPECIFICATIONS:

OPERATING VOLTAGE: 125 VDC / 120 VAC
 THRESHOLD VOLTAGE: 16 VDC / 20 VAC
 OPERATING RANGE: 30 - 140 VDC / 30 - 140 VAC
 CURRENT AT RATED VOLTAGE: 4.6 / 4.4 AMPS

ELECTRICAL RATINGS:

25 A/120 VAC 3 A/ 125 VDC
 15 A/240 VAC 1 A/ 250 VDC
 6 A/600 VAC

OVERLOAD CURRENT (50 OPERATIONS):

95 A/120 VAC
 65 A/240 VAC
 35 A/600 VAC

DIELECTRIC STRENGTH: 2200 VRMS

INSULATION RESISTANCE: 100 MEGOHMS INITIAL

CONTACT RESISTANCE: 10 MILLIOHMS MAX. INITIAL

DECK	CONTACTS	POSITION	
		TRIP	RESET
1	11 - 13		X
	12 - 18	X	
	15 - 17		X
	16 - 14	X	
2	21 - 23		X
	22 - 28	X	
	25 - 27		X
3	26 - 24	X	
	31 - 33		X
	32 - 38	X	
4	35 - 37		X
	36 - 34	X	
	41 - 43		X
	42 - 48	X	
5	45 - 47		X
	46 - 44	X	
	51 - 53		X
	52 - 58	X	
	55 - 57		X
	56 - 54	X	

DESCRIPTION

7605D 125VDC EXD

REV. A

LOCK-OUT RELAYS (LOR)

GENERAL OPERATION:

THE HANDLE OF THE LOR MUST BE MANUALLY ROTATED CLOCKWISE TO PLACE THE UNIT IN THE "RESET" POSITION (SEE FIGURE A)





FIGURE A - RESET POSITION

WHEN A PREDETERMINED CONDITION EXISTS, A SIGNAL WILL BE SENT TO S1 WHICH WILL ACTIVATE THE COIL AND CAUSE THE LOR TO "TRIP". THE "B" AND "G" CONTACTS ON THE CONTROL DECK PROVIDE THE CONNECTION TO THE CONTROL CIRCUIT THROUGH S1 WHICH CAN BE A CONTACT OF ANY TYPE I.E. SWITCH, RELAY, THE LOR CONTACTS IN FIGURE "B" ARE IN THE "TRIPPED" POSITION. THE LOR WILL REMAIN IN THE "TRIPPED" POSITION UNTIL MANUALLY RESET.





FIGURE B - TRIPPED POSITION



DESCRIPTION

7605D 125VDC EXD

REV. A

SHALLCO
 AN ISO 9001 COMPANY
 308 COMPONENTS DRIVE
 SMITHFIELD, NC 27577 USA