

SPECIFICATIONS:

NO. OF POSITIONS: 2, TRIP AND RESET

NO. OF SECTIONS: 9

CONTACTS: 2 NORMALLY OPEN

2 NORMALLY CLOSED

PER DECK

ACTION: 45° POSITIVE TRIP DETENT

STATIONARY CONTACTS: SILVER OVER COPPER

NAMEPLATE: AS SHOWN

COIL SPECIFICATIONS:

OPERATING VOLTAGE: 125 VDC / 120 VAC THRESHOLD VOLTAGE: 16 VDC / 20 VAC OPERATING RANGE: 30 - 140 VDC / 30 - 140 VAC CURRENT AT RATED VOLTAGE: 4.6 / 4.4 AMPS

ELECTRICAL RATINGS:

25 A/120 VAC 3 A/ 125 VDC

15 A/240 VAC 1 A/ 250 VDC

6 A/600 VAC

OVERLOAD CURRENT (50 OPERATIONS):

95 A/120 VAC 65 A/240 VAC 35 A/600 VAC


DIELECTRIC STRENGTH: 2200 VRMS

INSULATION RESISTANCE: 100 MEGOHMS INITIAL

CONTACT RESISTANCE: 10 MILLIOHMS MAX. INITIAL

		POSITION	
DECK	CONTACTS	TRIP	RESET
	11 ⊶	X	Х
1	12 ⊶	\boxtimes	
	15 ⊶		Х
	16 ⊶	\boxtimes	
2	21 •——— 23		Х
	22	\geq	
	25 ⊶ → 27		\times
	26 ⊶	\geq	
	31 ⊶		${}$
3	32 ⊶ → 38	\geq	
	35 ⊶ → 37		\times
	36 ⊶⊩	\geq	
4	41 ⊶		\geq
	42 ⊶	\geq	
	45 ⊶		\geq
	46 ⊶	\boxtimes	

		POSITION	
DECK	CONTACTS	TRIP	RESET
	51 ⊶⊩⊩⊸ 53		Х
5	52 ←	\boxtimes	
	55 ⊶	<u> </u>	\times
	56 ⊶	\boxtimes	
6	61 ←		\times
	62 ⊶	\boxtimes	
	65 ⊶		\times
	66 ⊶⊩⊩⊸ 64	\boxtimes	
	71 ←		\times
7	72 ←	\boxtimes	
	75 ⊶		\times
	76 ⊶⊩⊩⊸ 74	\boxtimes	
8	81 ←		X
	82 ←	\boxtimes	
	85 ⊶		Х
	86 ⊶⊩⊩ 84	\boxtimes	
	91		\times
9	92 ⊶	\boxtimes	
	95 ⊶		\times
	96 ⊶⊩⊩⊸ 94	\boxtimes	



DRILLING DIMENSIONS

LOCK-OUT RELAY SPECIFICATION SHEET



308 COMPONENTS DRIVE SMITHFIELD, NC 27577 USA

7609D

REV.-

ADDITIONAL INFO ON BACK

 REVISIONS


 LTR
 DESCRIPTION
 DATE | APP'D

LOCK-OUT RELAYS (LOR)

GENERAL OPERATION:

THE HANDLE OF THE LOR MUST BE MANUALLY ROTATED CLOCKWISE TO PLACE THE UNIT IN THE "RESET" POSITION (SEE FIGURE A)


FIGURE A - RESET POSITION



WHEN A PREDETERMINED CONDITION EXISTS, A SIGNAL WILL BE SENT TO S1 WHICH WILL ACTIVATE THE COIL AND CAUSE THE LOR TO "TRIP". THE "B" AND "G" CONTACTS ON THE CONTROL DECK PROVIDE THE CONNECTION TO THE CONTROL CIRCUIT THROUGH S1 WHICH CAN BE A CONTACT OF ANY TYPE I.E. SWITCH, RELAY.... THE LOR CONTACTS IN FIGURE "B" ARE IN THE "TRIPPED" POSITION.

THE LOR WILL REMAIN IN THE "TRIPPED" POSITION UNTIL MANUALLY RESET.

FIGURE B - TRIP POSITION



LOCK-OUT RELAY SPECIFICATION SHEET

SHALLED
AN ISO 9001 COMPANY

308 COMPONENTS DRIVE

SMITHFIELD, NC 27577 USA

DEV/

7609D